

AWWA C906 Pipe Sizes
All Dimensions Shown in inches

Nominal Pipe Size	IPS Outside Diameter	OD Tolerance	Minimum Wall DR 9	Minimum Wall DR 11
4	4.500	+/-0.020	0.500	0.409
5	5.563	+/-0.025	0.618	0.506
6	6.625	+/-0.030	0.736	0.602
7	7.125	+/-0.032	0.792	0.648
8	8.625	+/-0.039	0.958	0.784
10	10.750	+/-0.048	1.194	0.977
12	12.750	+/-0.057	1.417	1.159
13	13.275	+/-0.060	1.475	1.207
14	14.000	+/-0.063	1.556	1.273
16	16.000	+/-0.072	1.778	1.455
18	18.000	+/-0.081	2.000	1.636
20	20.000	+/-0.090	2.222	1.818
21.5	21.500	+/-0.097	2.389	1.955
22	22.000	+/-0.099	2.444	2.000
24	24.000	+/-0.108	2.667	2.182
26	26.000	+/-0.117	2.889	2.364
28	28.000	+/-0.126	3.111	2.545
30	30.000	+/-0.135	3.333	2.727
32	32.000	+/-0.144	3.556	2.909
34	34.000	+/-0.153	3.778	3.091
36	36.000	+/-0.162		3.273
42	42.000	+/-0.189		3.818